


LIFTING AND CARRIAGE PRECAUTIONS

- Check the weight on the CE label to select appropriate lift equipment .
- Before lifting the unit make sure that the external panel is firmly fixed in place.
- To use only lifting points provided.
- The chains or slings must be of equal length.
- To use a spread-bar to avoid damage to the unit.
- The movement must be performed with caution and avoid abrupt movements.
- Never move the unit on rollers.
- Never lift the unit using a fork-lift.



LEGEND

HPG	High pressure gauge (Opt)
LPG	Low pressure gauge (Opt)
ATS	Spring type antivibrant mounting (Opt)
ATV	Rubber type antivibrant mounting (Opt)

MOD.	EMPTY WEIGHT	OPERATING WEIGHT	HYDRAULIC CONNECTIONS
SBS.190	1900 kg	1950 kg	DN125
SBS.240	2250 kg	2320 kg	DN125
SBS.290	2350 kg	2450 kg	DN125
SBS.330	2400 kg	2500 kg	DN125

Scala-Scale	Data-Date	Dis.to-Drawn	N°Pezzi	HITEMA®
	15/09/16	B.P.		
Peso-Weight Kg.	Materiali-Materials			
Denominazione-Denomination				DIS.-DRAW N.
WATER CHILLERS mod. SBS.190÷330/CS.ST.NT.NP.				DIM-SBS-190ST01
Particolare-Detail				Rev.
Overall dimension - Lift Instruction				00
REFRIGERANT R410a				PROGRAM.N.